

ROCKERY HEIGHT (FT)	EMBEDMENT (D)	MIN ROCK SIZE (BASE)	MIN ROCK SIZE (TOP)		
2	3 INCHES	2-MAN	1-MAN		
4	6 INCHES	3-MAN	2-MAN		
6	9 INCHES	4-MAN	2-MAN		
7	12 INCHES	5-MAN	2-MAN		

<u>NOTES</u>

- 1. ROCKERY MUST BE INSTALLED BY LICENSED CONTRACTOR.
- 2. IF ROCKERY HEIGHT EXCEEDS 4', IT MUST BE DESIGNED BY A PRACTICING GEOTECHNICAL/CIVIL ENGINEER LICENSED IN THE STATE OF WASHINGTON.
- 3. FILTER FABRIC SHALL BE MIRAFI 140 N SERIES OR APPROVED EQUAL.
- 4. APPROVED 6" PERF PVC DRAINLINE TIE TO PUBLIC STORM SYSTEM MUST BE INSPECTED BY PUBLIC WORKS.

STANDARD DETAIL ROCKERY DETAIL SIDEWALK SUPPORT



ONS	INITIAL										
REVISIONS	DATE										
DATE DRAWN	10/22/2020			DATE APPROVED	DATE APPROVED						
SCALE: AS SHOWN	DRAWN	CAW	37		STANDARD SPECIFICATIONS						
		DESIGNED		APPROVED BY		STAN					
DETAIL NO. R-410											

1 OF 2