



## <u>NOTES</u>

- 1. STEPS SHALL BE 4'-0" WIDE, CURB TO CURB, PLUS 6" CURBS ON EACH SIDE.
- 2. CEMENT CONCRETE SHALL BE CLASS 4000 TROWEL FINISH.
- 3. NUMBER OF STEPS SHALL SUIT INDIVIDUAL CONDITIONS, WITH TREAD AND RISER DIMENSIONS TO SUIT THE GRADE.
- 4. RISERS SHALL BE 5" MINIMUM, 7" MAXIMUM: TREAD SHALL BE 11" MINIMUM, 12" MAXIMUM.
- 5. HANDRAIL REQUIRED ON BOTH SIDES PER BUILDING CODE STANDARDS.
- 6. HANDRAIL MAY NOT ENCROACH INTO PUBLIC SIDEWALK.

## STANDARD DETAIL CEMENT CONCRETE

**STEPS** 





SCALE: AS SHOWN

O/23/2020
DESIGNED
CAW

APPROVED BY
DATE OPRAWN
CHECKED
CAW
THE APPROVED BY
STANDARD SPECIFICATIONS

R-900 PAGE **1 OF 1**