



NOTES

1. TRENCH BACKFILL BELOW TOP 4 FEET MAY BE NATIVE MATERIALS OR AS REQUIRED BY THE SPECIFICATIONS, OR AS DIRECTED BY THE PUBLIC WORKS INSPECTOR.
2. MINIMUM TRENCH WIDTH SHALL BE PIPE ID + 24".
3. IN PAVED AREAS USE CRUSHED ROCK BACKFILL
 - * FULL DEPTH OF TRENCH WHERE SEWER MAIN CROSSES PERPENDICULAR TO THE TRAVELED LANE OR DRIVEWAY.
 - * TOP FOUR FEET WHERE SEWER MAIN RUNS PARALLEL TO THE TRAVELED LANE, UNLESS EXISTING MATERIAL IS DETERMINED BY THE ENGINEER TO BE SUITABLE FOR BACKFILL.
4. THE STREET SHALL BE OVERLAID WHEN THE ASPHALT ROADWAY IS LESS THAN 5YRS OLD FOR UTILITY CROSSINGS, THE STREET SHALL BE OVERLAID AT LEAST 25 FEET ON EACH SIDE OF THE TRENCH.

**STANDARD DETAIL
SANITARY SEWER
TRENCH**



SCALE: AS SHOWN	DESIGNED	CHECKED	DATE DRAWN	DATE	INITIAL
	APPROVED BY	CAW	11/06/2020		
APPROVED BY			DATE APPROVED	STANDARD SPECIFICATIONS	

DETAIL NO.
S-200

PAGE
1 OF 1