



TABLE 1  
WATER MAIN STANDARD PIPE MATERIAL

AWWA STANDARD			
TYPE OF PIPE	PIPE	JOINT	FITTINGS
DUCTILE IRON	C 1.52	C 111	C 110
CONCRETE CYLINDER	C 303		

**NOTE:**

1. TO BE USED WHEN 10' MINIMUM SEPARATION CANNOT BE OBTAINED.

**STANDARD DETAIL  
WATER AND SEWER  
SPACING & CLEARANCE**



SCALE: AS SHOWN	DESIGNED	DRAWN	CHECKED	DATE DRAWN	REVISIONS
	APPROVED BY	CAW	DATE APPROVED	12/04/2020	DATE
STANDARD SPECIFICATIONS					INITIAL

DETAIL NO.  
**S-210**

PAGE  
**1 OF 1**