



NOTES:

1. DEPTH OF CHANNEL MUST BE SAME AS PIPE DIAMETER.
2. MINIMUM 0.1' DROP ACROSS CHANNEL;
MAXIMUM 1.0' DROP ACROSS CHANNEL.

**STANDARD DETAIL
SEWER MANHOLE MAIN
CHANNEL & SHELF**



SCALE: AS SHOWN	DESIGNED	DATE DRAWN	REVISIONS
	DRAWN CAW	12/04/2020	DATE INITIAL
APPROVED BY	CHECKED	DATE APPROVED	
STANDARD SPECIFICATIONS			

DETAIL NO.
S-400

PAGE
1 OF 1