



NOTES:

1. CALL FOR CLEAR AND GRADE INSPECTION PRIOR TO BASE COURSE BEING PLACED. VERIFICATION OF ROCKERY HEIGHT, FOUNDATION MATERIAL, AND ROCK SIZE BY CITY CLEAR AND GRADE INSPECTOR IS REQUIRED.
2. 4-INCH TO 6-INCH QUARRY SPALLS SHOULD BE PLACED DIRECTLY FROM TRUCK OR OTHER SUITABLE CONTAINER IN ORDER TO MAINTAIN CLEAN BACKFILL.
3. SPALLS MAY NOT BE NEEDED AT BASE OF ROCKERY IF NATIVE FOUNDATION MATERIAL IS SUITABLE AS DETERMINED BY THE GEOTECHNICAL ENGINEER OR THE CITY CLEARING AND GRADING INSPECTOR.
4. OPENINGS CHINKED WITH QUARRY SPALLS.
5. IF ROCKERY HEIGHT EXCEEDS 4-FEET, IT MUST BE DESIGNED BY A PRACTICING GEOTECHNICAL/CIVIL ENGINEER LICENSED IN THE STATE OF WASHINGTON. NO ROCKERY SHALL BE GREATER THAN 7-FEET IN HEIGHT UNLESS APPROVED BY CITY.
6. A ROCKERY GREATER THAN 4-FEET IN HEIGHT AND ON PRIVATE PROPERTY SHALL REQUIRE A BUILDING PERMIT WITH A THIRD PARTY INSPECTION TO BE CONSTRUCTED.
7. FILTER FABRIC SHALL BE MIRAFI 140 N SERIES OR APPROVED EQUAL.
8. OUTLET OF PERFORATED PIPE TO BE DETERMINED BEFORE CONSTRUCTION.

**STANDARD DETAIL
ROCKERY WALL
IN ROW**



SCALE: AS SHOWN	DATE DRAWN 12/4/2020	REVISIONS		
		DATE	INITIAL	
DESIGNED	CHECKED	01/01/2022	AJS	
APPROVED BY	DATE APPROVED	03/31/2023	JTB	
DRAWN CAW				
STANDARD SPECIFICATIONS				