



- NOTES:**
1. STEPS SHALL BE 4- FEET - 0-INCH WIDE, CURB TO CURB, PLUS 6-INCH CURBS ON EACH SIDE.
  2. CEMENT CONCRETE SHALL BE CLASS 4000 TROWEL FINISH.
  3. NUMBER OF STEPS SHALL SUIT INDIVIDUAL CONDITIONS, WITH TREAD AND RISER DIMENSIONS TO SUIT THE GRADE.
  4. RISERS SHALL BE 5-INCH MINIMUM, 7-INCH MAXIMUM: TREAD SHALL BE 11-INCH MINIMUM, 12-INCH MAXIMUM.
  5. HANDRAIL REQUIRED ON BOTH SIDES PER BUILDING CODE STANDARDS.
  6. HANDRAIL MAY NOT ENCROACH INTO PUBLIC SIDEWALK

**STANDARD DETAIL  
CEMENT CONCRETE  
STEPS**



SCALE: AS SHOWN	DATE DRAWN 0/23/2020	REVISIONS			
		DATE	INITIAL	DATE	INITIAL
DESIGNED	CHECKED	01/01/2022	AJS		
APPROVED BY	DATE APPROVED	03/31/2023	JTB		
STANDARD SPECIFICATIONS					