


- 9. OPTIONAL CLEANOUT CONFIGURATION







**CLEANOUT FRAME AND COVER** 

## NOTES:

CONCRETE PAD REQUIRED ONLY IN AREAS SUBJECT

TO MOTOR VEHICLE TRAFFIC OR IN SIDEWALK.

EDGE OF FRAME

6-INCH

-14-INCH DIA DUCTILE IRON PIPE, 12-INCH LONG

-6-INCH OF 3-INCH PEA GRAVEL MEETING STANDARD SPECIFICATION 9-03.1(2)B GRADATION REQUIREMENTS FOR 3-INCH SIEVE

-6-INCH CRUSHED SURFACING

TOP COURSE

#4 REBAR, TIED

**CLEANOUT PLAN VIEW** 

**CLEANOUT DETAIL** 

- CLEANOUT FRAME AND COVER SEE DETAIL 3

- VERTICAL RISER

- MIN. 6-INCH DIA TEE-WYE

THREADED PLUG OR CAP WITH

MIN.  $4'-0" \times 2'-6" \times 1'-0"$ 

CONCRETE OR PAVEMENT -

COMPACTED SUBGRADE


SQUARE OPERATING NUT -


MIN. 6-INCH DIA TEE-WYE-

CONC PAD -

(TYP.)

- ALL CONNECTIONS MUST BE APPROVED BY THE CITY OF WENATCHEE AND INSTALLED PER MANUFACTURER RECOMMENDATIONS.
- 2. THE SANITARY SEWER LATERAL, INCLUDING THE TAP, SADDLE, TEE, PIPE, AND CLEANOUT IS CONSIDERED "PRIVATE" UPSTREAM OF THE MAIN LINE POINT OF CONNECTION.
- MINIMUM 6-INCH DIAMETER CLEANOUTS SHALL BE CONSTRUCTED ON ALL SEWER LATERALS. THE VERTICAL RISER SHALL BE OF EQUAL SIZE AS THE LATERAL PIPE OR LARGER.
- 4. CLEANOUTS MAY BE LOCATED IN THE PLANTER STRIP AT THE BACK OF WALK, IF ONE EXISTS, AND SHALL BE VISIBLE AT FINISHED GRADE. CLEANOUTS LOCATED BELOW FINISHED GRADE SHALL HAVE
- CLEANOUT FRAME AND COVER SHALL BE HEAVY DUTY, BOLT DOWN EAST JORDAN MODEL 3675 OR APPROVED EQUAL AND LABELED "SEWER" OR "CLEANOUT".
- MAXIMUM CENTER-TO-CENTER SPACING BETWEEN CLEANOUTS SHALL BE 2'-0". MODIFICATIONS TO THIS SPACING REQUIRE THE APPROVAL
- 7. CONCRETE PAD FC' SHALL BE 3,000 PSI OR GREATER.
- 8. ALL #4 REBAR SHALL HAVE 2-INCH MINIMUM COVER.







## DETAIL SEWER CLEANOUT **STANDARD** SANITARY DOUBLE



7-08 7-18 7-19 AS DETAIL NO.

S-120

PAGE

1 OF 1