



NOTES:

1. TRENCH BACKFILL BELOW TOP 4 FEET MAY BE NATIVE MATERIALS OR AS REQUIRED BY THE SPECIFICATIONS, OR AS DIRECTED BY THE PUBLIC WORKS INSPECTOR.
2. MINIMUM TRENCH WIDTH SHALL BE PIPE ID +24-INCH. MAX WIDTH NOT TO EXCEED 6- FEET.
3. SEE CITY OF WENATCHEE POLICY R-2, AND STANDARD DETAIL R-310 FOR OVERLAY REQUIREMENTS.

**STANDARD DETAIL
STORM AND SEWER
TRENCH**



SCALE: AS SHOWN	DATE DRAWN 11/06/2020	REVISIONS	
		DATE	INITIAL
DESIGNED	CHECKED	01/01/2022	AJS
APPROVED BY	DATE APPROVED	03/31/2023	JTB
STANDARD SPECIFICATIONS			

DETAIL NO.
S-200

PAGE
1 OF 1