



NOTES:

1. WATER METER LIDS SHALL BE "IFCO": NO. 2019 TO BE USED IN DRIVEWAYS, NO. 2020 WITH DROP HANDLES TO BE USED IN SIDEWALK AREAS
2. AIR VALVE ASSEMBLY SHALL BE INSTALLED AT HIGHEST POINT OF LINE.
3. REBAR STAKE TO SUPPORT VALVE. TWO MAY BE NEEDED.

SOFT SEAT COMBINATION AIR RELEASE/VACUUM VALVE (THREADED), SIZE AS REQUIRED BY CITY, APCO #143C OR 145C, OR VAL-MATIC MODEL 201.C OR 202.C, NO SUBSTITUTIONS.

ALL PIPE FITTINGS AFTER CURB STOP TO BE GALVANIZED STEEL (WRAPPED), UNLESS OTHERWISE NOTED. PIPE FROM MAIN TO CURB STOP SHALL NOT BE GALVANIZED STEEL.

COMBINATION AIR VALVE
N.T.S.

STANDARD DETAIL
COMBINATION
AIR VALVE



SCALE: AS SHOWN	DESIGNED	DRAWN	CHECKED	DATE DRAWN	REVISIONS			
					DATE	INITIAL	BY	DATE
		RLK	SK	08/03/2006	12/21/2020	CAW		
					01/01/2022	AS		
					03/31/2023	JTB		

DETAIL NO.
W-400

PAGE
1 OF 1